

# Electric Power Group Presents Maximizing Use of Synchrophasor Technology for Everyday Tasks

## Welcome!

The meeting will begin at

2:00 p.m. EDT / 11:00 a.m. PDT  
Sept. 21, 2016

Registration URL: <https://electricpowergroup2.webex.com/>

Webinar Teleconference Number: 1-650-479-3208

Access code: 665 878 354

**Please mute your phone during the presentation.**

We will encourage discussion at planned QA session.

Thank you for your cooperation.

For any technical issues with this webinar, please contact [Kosareff@electricpowergroup.com](mailto:Kosareff@electricpowergroup.com) or call (626) 685-2015

**Maximizing Use of Synchrophasor Technology for Everyday Tasks**

**Quickly Creating Reports on Grid Performance  
and Events for  
Operators, Engineers and Managers**

**Webinar**

**Sept 21, 2016**

Presented by

Kevin Chen, Neeraj Nayak, EPG

Sidharth Rajagopalan, Patrick Gravois, ERCOT

# Outline

---

- **Reports - Needs & Solutions**

- > Daily Operations Performance

- > Event Reports & Root Cause Diagnosis – Generation Trip, Oscillations, Faults, Line Trips etc.

- Real-Time report for Operators

- On Demand report for Reliability Coordinators & Managers

- Offline analysis report for Engineers & Planners

- > Reports - Summary

- **ERCOT Experience**

- **Discussion**

- > Your Practice, Use Cases, Suggestions

- **Summary**

# Reports That Operators, Engineers and Managers May Need

---

- Daily Operation Performance – Highlights from Previous Day
- Event Root Cause Diagnostics
- Gen Trip and Frequency Response
- Oscillation Events Root Cause Analysis
- Model Validation
- Fault Analysis
- Data Quality

# Daily Operations Performance

# Daily Operations Performance

---

- **Need – Quick Review of Previous Day’s Operating Highlights**
- **Sample Daily Report Content**
  - > Top 10 Events
  - > System Alarm Summary
  - > Oscillation Events
  - > Max/Min Phase Angles
  - > Frequency, Voltage Daily Performance
  - > Key Substation PMU Data Quality Performance
- **Automatic Distribution by Email**



# Event Reports & Root Cause Diagnosis



# Event Reports

Type of Report	Primary User	Need	Report Info	Example
Real-Time	Operator	<ul style="list-style-type: none"> <li>Monitor</li> <li>Diagnose</li> <li>Act</li> </ul>	Location of the event Type of event Current Situation Severity of the event Key Metrics	
Near Real-Time/ On Demand	Operating Engineer Reliability Coordinator, Management	<ul style="list-style-type: none"> <li>Stay Informed on current system conditions &amp; events</li> <li>On demand customized reports e.g., PMU performance over last 3 -months</li> <li>Periodic system alarms and event summary e.g., How many events in last 3-months?</li> </ul>	<b>Generation Trip:</b> Location of the Unit trip Largest voltage dip & largest voltage deviation, Largest angle swing NERC Frequency response points A,B,C Ringdown analysis results – mode estimate (frequency, damping) and mode shape <b>Oscillation Event:</b> Modal Frequencies present in the signal, Identify root cause e.g., control system issues. Damping % and Energy of the oscillation <b>Data Quality, PMU Performance</b>	
Offline Analysis	Operating Engineer Planner Protection Engineer	<ul style="list-style-type: none"> <li>Validate system performance</li> <li>Alarms and Settings</li> <li>Relay Operation</li> <li>Fault Analysis</li> <li>Validate models</li> </ul>	Plot Analysis, Modal Analysis, Spectral Analysis, Ringdown analysis, Frequency response, Fault analysis, model validation, Statistical analysis, sensitivity analysis	

# Event Root Cause Diagnostics

*Real Time Report for Operators*

# Real-Time Needs

---

- Be aware of the current situation – Monitor
- Diagnose the event when it happens
  - > Where did the event occur – location?
  - > What is the type of the event?
  - > How severe is the event and what action might be required?
- Take action to bring the system back to normal conditions
- Event metrics at operators' fingertips

# Real-Time Event Analyzer Report

## Event Metrics at A Glance for Operator Assessment and Action

- **Monitor multiple events**

- > Oscillations
- > Voltage and Angle Sensitivity
- > Islanding
- > Generation/Load Trip
- > Composite Alarms


- **Show associated event information**

- > Location
- > Type
- > Occurrence time
- > Participating PMUs

- **Present relevant information only**


- **Displays**

- > Templates of critical metrics
- > Dynamic signals
- > Automated on the fly




# Event Analyzer Pop-up Shows Event Type & Location

## Example: Detection of Oscillations



**Low Damped Oscillation Event Analyzer pop-up showing Event Type and Location**

# Event Analyzer Report - Event Location, Metrics, Severity



# Event Reports

*On Demand Report for Reliability Coordinators & Managers*

# On-Demand & Near Real-Time Needs

---

- Comparison Performance
  - > Prior Day vs. Today
  - > Peak Day vs. Today
- Quick Review of Recent Performance
  - > Last Hour, Last Shift, Last 24-Hours
- Periodic Performance Trends – weekly, monthly
  - > Events, Alarms
  - > Types, Severity
  - > Key Substation Locations
- Detailed Event Report
  - > Frequency Response, First Responding PMU, Largest Swing
  - > Oscillation Location, Damping, Energy



# On Demand Event Reports Contents

---

## ■ Generation Trip Report

- > Location of the generation trip – First responding PMU
- > Largest voltage dip and largest voltage deviation
- > Largest angle swing and location
- > NERC frequency response points A,B,C (Lowest point)
- > Ringdown analysis results – mode estimate (frequency, damping) and mode shape

## ■ Oscillation Report

- > Oscillation type – Inter-area, local controller
- > Damping %
- > Energy of the oscillation
- > Source of oscillations – Wind farms, HVDC, Nuclear, Hydro

# Example: Gen Trip Report

## Event Location and Description

Event Summary

Reported Event Title:

Event Date/Time: Peachon@HWRD.Frequency.Frequency - L1 Tripped @ 4/25/2016 1:27:59 PM PDT

Submitted Date/Time: Follow up Submitted Date:

1. Author:

Contact Email and Phone #:

2. Brief Description of Event:

3. Generation Tripped Off-line:

4. Frequency:

MW Total:	Pre Disturbance Frequency (Hz)- A:	59.97396
Unit(s) Tripped:	Lowest Frequency following frequency disturbance (Hz)- C:	59.912
	Frequency Recovery Time:	53.133 seconds

5. Reserves Deployed by SCED

6. Physical Responsive Capability:

Responsive Reserve	Just prior to disturbance(MW):	
Max-5min	Immediate Recovery Frequency Recovery Time(MW):	
	Frequency Recovery Time(MW):	

7. Restoration time for Unit(s):

8. Energy Price

	Prior to disturbance(\$)	
	Maximum during event(\$)	
	After Frequency Recovery(\$)	

9. Cause of Event

10. Additional Comments

4/25/2016 1:28:55 PM PDT ©2016 Electric Power Group. All rights reserved. Page 1 of 3

## Event Metrics

Frequency Drop (Hz)	Drop Time (Point A - C)(seconds)	Stabilization Time (Point C - B)(seconds)
6.06198831	19.3	13.853

PMU Frequency data(Fig.1):

PMU location (with the largest frequency dip)	Point A Frequency (Hz)	Point C Frequency (Hz)	Point B Frequency (Hz)
CPSSW 8070.Frequency	59.97396	59.912	59.94271

PMU Voltage Magnitude data(Fig.2):

PMU Location (with the largest voltage dip)	Pre-Event Highest Voltage	Lowest Voltage Recorded	Voltage Deviation
CPSSW 8070.VCPM	352.941	351.645	0.296


Reference Bus: KLN5W 5020.V1LPM

PMU Voltage Angle data(Fig.3):


PMU Location (with the largest angular swing)	Pre-Event Angle (degree)	Post Event Angle (degree)	Angle Deviation (degree)	Largest Swing (degree)	Dynamic Swing Time (seconds)
EXPXY 9145.VALPM	-1.272	-0.562	-0.710	-0.937	25.000

4/25/2016 1:28:55 PM PDT ©2016 Electric Power Group. All rights reserved. Page 2 of 5

## Frequency & Voltage Response



## Ringdown Analysis



# Event Root Cause Diagnostics

*Offline Analysis Report for Engineers & Planners*


# Offline Analysis Needs

---


- Did the Grid Perform as Planned?
- Are Alarm & Parameters Set Correctly?
- Are the System and Power Plant Models Valid?
- Are the Protection Settings Correct?
- What's the Root Cause and Sequence of the Event?

# Offline Analysis - PGDA


## Using PMU Event Signatures for Classification of the Event




**A: Drop, Rebound and Slow Recovery - Generation Trip**



**C: Transient and Ringdown - Line Trip**




**E: Rise and Slow Recovery - Load Trip**




**G: Oscillations**



**B: Sharp Change and Immediate Recovery**



**D: Transient and Drop - Line Trip and Generation Trip**



**F: Separation - 2 Signals : Islanding**

**7 Typical Event Signatures from Event Analysis**

# Example of PGDA Report

## Event Summary

4/12/13 18:00 - 22:00 John Balance

### Summary

#### Data Source

Data Source: C:\Users\JohnB\Documents\Consulting\EPG\... \Synchronphasor Project\RTDMS  
 Daily Report... \Event Files\Event20130412\... \1800\_60m.csv  
 Source 2: C:\Users\JohnB\Documents\Consulting\EPG\... \Synchronphasor Project\RTDMS  
 Daily Report... \Event Files\Event20130412\... \1800\_60m.csv  
 Source 3: C:\Users\JohnB\Documents\Consulting\EPG\... \Synchronphasor Project\RTDMS  
 Daily Report... \Event Files\Event20130412\... \12000\_60m.csv  
 Source 4: C:\Users\JohnB\Documents\Consulting\EPG\... \Synchronphasor Project\RTDMS  
 Daily Report... \Event Files\Event20130412\... \12100\_60m.csv  
 Total Signals: 3  
 Data Starts: 2013-04-13 19:59:59.967  
 Data Ends: 2013-04-13 22:00:00.000  
 Data Time Zone: CDT  
 Analysis Time Zone: CDT

#### Notes

This analysis examines the voltage magnitude synchronphasor signal from the ... PMU on the evening of April 12, 2013, prior to the ... Outage Event on the early morning of April 13, 2013. As noted in the ... Outage report, a strong 2 Hz oscillation was evident for several hours prior to the actual outage event, and the oscillation ended immediately upon the trip of the ... Wind Farm.

The 2 Hz oscillation which was evident immediately prior to the ... outage on 4/13/13 was present on the evening of April 12, although at small magnitude, as early as 18:00 on 4/12/13. At about 20:35, the oscillation magnitude sharply increased, and continued throughout the remainder of this study period.

The current magnitude phasor ... indicates that the ... generation was not a participant in the oscillations. Moreover, the frequency phasor indicates that the 2 Hz oscillation was not triggered by any identifiable grid generator/load imbalance (which would have been observed by a sudden change in frequency).

Due to the sharp change in magnitude of the 2 Hz oscillation at about 20:35, it appears that the oscillation is the result of a malfunctioning voltage control system somewhere near the ... PMU. Note that voltage oscillations created at one location on the grid can often be measured at several other locations on the grid. In this case, it is most likely that the voltage oscillations are being caused by generation near, but not at, ... .


## Plot Analysis

4/12/13 18:00 - 22:00 John Balance

18:00-22:00

**Pre-Process Options**  
 DownSampling : False  
 Normalization : None  
 Differentiate : False  
 Resampling : False, DownSampling, 30  
 FilterAbnormalData : False  
 Interpolation : None, 70%  
 LowPass : False, 100, 5  
 Detrending : None

**Post-Process Options**  
 PlotType : TimeSeries  
 WindowSize : 11  
 GroupSize : 11



This plot of the Frequency, Current Magnitude, and Voltage Magnitude phasors measured at ... illustrate the presence of the 2 Hz oscillation [oscillations increase sharply]


## Plot Analysis

4/13/13 1:30:05 PM John Balance

IM VM

**Pre-Process Options**  
 DownSampling : False  
 Normalization : None  
 Differentiate : False  
 Resampling : False, DownSampling, 30  
 FilterAbnormalData : False  
 Interpolation : None, 70%  
 LowPass : False, 100, 5  
 Detrending : None

**Post-Process Options**  
 PlotType : TimeSeries  
 WindowSize : 110  
 GroupSize : 110



Plot of ... current and voltage magnitudes for entire five-hour data extract. Note that there is no significant oscillation in the ... current magnitude, while the voltage signal shows voltage conditions. This suggests ... generators were not the source of the oscillations.

## Modal Analysis


4/12/13 18:00 - 22:00 John Balance

Modal Analysis 18:00-22:00

**Pre-Process Options**  
 Resampling : True, DownSampling, 30  
 FilterAbnormalData : False  
 Interpolation : None, 70%  
 LowPass : False, 100, 5  
 Detrending : None

**Algorithm Options**  
 ProcessTimeWindow : 160  
 StepInterval : 5  
 ARIIndex : 125  
 MAIndex : 110  
 NPointsARCoef : 110  
 DampFac : 1.0  
 FRange : 10, 1, 3, 2  
 EstMaxWin : 10, 1  
 NFFT : 130  
 NRoot : 10  
 EstimateOfMaxModesNumber : 10  
 ModeTolerance : 10, 1

**Post-Process Options**  
 BootstrapConfidenceLevel : 75



This modal analysis of ... voltage magnitude signal from 18:00-22:00 shows the 2 Hz oscillation was present throughout the period, changing from an initial frequency of about 1.9 Hz to 2.0 Hz at 20:35. Note also that the amplitude of the oscillation increases dramatically at 20:35.

The second mode present, at about 3 Hz, is a much smaller oscillation, but it also demonstrates the same characteristics as the 2 Hz mode, present throughout the period, and increasing sharply at 20:35.

## Modal Analysis


4/13/13 1:30:05 PM John Balance

VM 3 hours

**Pre-Process Options**  
 DownSampling : True, DownSampling, 30  
 FilterAbnormalData : False  
 Interpolation : None, 70%  
 LowPass : False, 100, 5  
 Detrending : None

**Algorithm Options**  
 ProcessTimeWindow : 160  
 StepInterval : 5  
 ARIIndex : 125  
 MAIndex : 110  
 NPointsARCoef : 110  
 DampFac : 1.0  
 FRange : 10, 1, 4  
 EstMaxWin : 10, 0, 1  
 NFFT : 130  
 NRoot : 10  
 EstimateOfMaxModesNumber : 10  
 ModeTolerance : 10, 1

**Post-Process Options**  
 BootstrapConfidenceLevel : 75



This plot illustrates the modal analysis of the ... voltage signal from, midnight to 3:00 AM. Note the strong frequency oscillation at 1.90 Hz (essentially 2 Hz), which ends abruptly at about 2:30 AM, following the trip of the wind farm.

## Spectral Analysis


4/12/13 18:00 - 22:00 John Balance

VM & IM Spectral

**Pre-Process Options**  
 Resampling : True, DownSampling, 30  
 FilterAbnormalData : False  
 Interpolation : Linear, 70%  
 LowPass : False, 100, 5  
 Detrending : Linear

**Algorithm Options**  
 WindowType : hann  
 FFTWindowSize : 60  
 FFTOverlap : 60

**Post-Process Options**  
 AutoSpectrumNormalization : Power\_Spectrum\_Density  
 SpectrumScaler\_Mode : DB  
 Frequency\_Range : 0,10



This spectral analysis of the ... voltage magnitude and current magnitude signals illustrates that the 2 and 3 Hz oscillations are present in the voltage magnitude signal, but not in the current magnitude signal. This indicates that the ... generation is not contributing to the oscillations.]

# Reports - Summary

Reports	Real-Time (RTDMS)	On Demand (GridSmarts)	Offline (PGDA)
Daily Performance		✓	
Event Report	✓	✓	✓
Oscillations	✓	✓	✓
Generation Trip and Frequency Response	✓	✓	✓
Fault Analysis	✓		✓
Model Validation			✓
Data Quality		✓	

# ERCOT Experience





# ERCOT PMU Event Reporting

Patrick Gravois  
Grid Applications Support

**EPG Users Group WebEx  
September 21, 2016**


# ERCOT PMU Event Reporting

- Four metrics analyzed for each event with frequency dropping to 59.9 Hz and below
  - System frequency and location with largest frequency deviation
  - Location with the largest swing in voltage magnitude
  - Location with the largest voltage angle swing with respect to a reference PMU in central Texas
  - Ring-down analysis to calculate associated dominant mode(s) and damping
- The Phasor Grid Dynamics Analyzer (PGDA) application by EPG is used for this analysis
- Report is sent out internally


## Import PMU Data into PGDA

- For events such that frequency drops to 59.9 Hz or below, event files (COMTRADE) are automatically created by RTDMS
- For rare times that event file is not created, PMU data can be pulled into a .csv file using the ePDC Database Tool
- Either COMTRADE file or .csv file is loaded into PGDA
- COMTRADE File is more effective since the majority of bad data is filtered out
- Following slides show an analysis of a ~814 MW trip in September of 2015


# Frequency Time Series




# Event Analysis




# Voltage Magnitude Analysis



# Largest Voltage Sag Due to Fault




# Largest Voltage Sag Due to Loss of Generation







# Voltage Angle Analysis




# Largest Voltage Angle Swing




# Ring-Down Analysis of Largest Angle Swing



# Ring-Down Analysis of Largest Angle Swing



# Ring-Down Analysis of Largest Angle Swing



# First Frequency Response



# Q&A, Discussion

# Q&A, Discussion

- Q&A
- Event Report
  - Your Practices
  - Use Cases
  - Pain Points
  - Suggestions
- Next Webinar Focus
  - Priority
  - Other topics





# EPG Webinar Series

---

- **System Model Validation for MOD-33 Requirement (Oct. 12)**
- Configuring alarms and validate parameters to provide meaningful results for operators.
- Mining large data archives for events of different types, e.g. oscillations, generator trips, etc.
- Using alarms & events for proactive actions.
- Providing secure remote access to users in real-time for monitoring and diagnostics during normal times and emergencies.
- Sending data & alarms to EMS.
- Leveraging existing one-line diagrams to map synchrophasor data.
- Extending grid synchrophasor observability with Linear State Estimation technology.
- Other topics?
- Extracting large amounts of synchrophasor data efficiently for offline analysis. (August 2016)
- Quickly creating an event report that could be distributed to operators, engineers and managers. (Sept. 2016)

# Summary

---

- **Reports - Needs & Solutions**

- > Daily Operations Performance

- > Event Reports & Root Cause Diagnosis – Generation Trip, Oscillations, Faults, Line Trips etc.

- Real-Time report for Operators

- On Demand report for Reliability Coordinators & Managers

- Offline analysis report for Engineers & Planners

- **Quickly Creating Reports using *RTDMS, GridSmarts, PGDA***

- **ERCOT Experience**

- **Discussion**

*Thank you for participating!*

*If you have any questions regarding any part of the course,  
please contact us at [Contact@electricpowergroup.com](mailto:Contact@electricpowergroup.com)*

*<http://electricpowergroup.com/webinars.html>*



**Electric Power Group**

201 S. Lake Ave., Ste. 400  
Pasadena, CA 91101  
626-685-2015